

ICC-ES Evaluation Report

ESR-1215

Reissued November 2025

This report also contains:


- [CA Supplement](#)

Subject to renewal November 2026

- [FL Supplement](#)

ICC-ES Evaluation Reports are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this report, or as to any product covered by the report.

Copyright © 2025 ICC Evaluation Service, LLC. All rights reserved.

<p>DIVISION: 04 00 00— MASONRY</p> <p>Section: 04 71 00— Manufactured Brick Masonry</p> <p>Section: 04 73 00— Manufactured Stone Masonry</p>	<p>REPORT HOLDER:</p> <p>WESTLAKE ROYAL STONE LLC dba WESTLAKE ROYAL STONE SOLUTIONS</p>	<p>EVALUATION SUBJECT:</p> <p>ELDORADO STONE®, ELDORADO BRICK®, AND ELDORADO ADOBE® VENEERS</p>	
---	--	---	---

1.0 EVALUATION SCOPE

1.1 Compliance with the following codes:

- 2024, 2021, 2018 and 2015 [International Building Code® \(IBC\)](#)
- 2024, 2021, 2018 and 2015 [International Residential Code® \(IRC\)](#)

Properties evaluated:

- Veneer strength and durability
- Surface burning characteristics

1.2 Evaluation to the following green code(s) and/or standards:

- 2025 and 2022 [California Green Building Standards Code \(CALGreen\)](#), Title 24, Part 11
- 2020, 2015, 2012 and 2008 [ICC 700 National Green Building Standard™](#) (ICC 700-2020, ICC 700-2015, ICC 700-2012, and ICC 700-2008)

Attributes verified:

See Section 3.0

2.0 USES

Eldorado Stone, Eldorado Brick and Eldorado Adobe Veneers are used as adhered, non-load-bearing exterior veneers or interior finishes on wood or light gage steel stud walls, masonry walls and concrete walls.

3.0 DESCRIPTION

Eldorado Stone®, Eldorado Brick® and Eldorado Adobe® veneers are precast concrete products made to resemble natural stone, brick, or adobe, respectively, in color and in texture. The concrete is composed of cement, aggregate, water, admixtures, and coloring. The veneer units are molded and cured at the plant. Evaluated veneer styles are listed in [Table 1](#).

The precast veneer has a Class A finish rating in accordance with IBC Section 803.1.2 (2015 IBC Section 803.1.1) and complies with the flame-spread and smoke-development requirements of IRC Section R302.9.

The attributes of the precast veneers have been verified as conforming to the provisions of (i) CALGreen Section A4.405.1.3 for prefinished building materials and Section A5.406.1.2 for reduced maintenance; (ii) ICC 700-2020 Section 602.1.6 and 11.602.1.6 for termite-resistance materials and Sections 601.7 and 11.601.7 for site-applied finishing materials, (iii) ICC 700-2015 and ICC 700-2012 Sections 602.1.6 and 11.602.1.6 for termite-resistant materials and Sections 601.7, 11.601.7, and 12.1(A).601.7 for site-applied finishing materials; and (iv) ICC 700-2008 Section 602.8 for termite-resistant materials and Section 601.7 for site-applied finishing materials. Note that decisions on compliance for those areas rest with the user of this report. The user is advised of the project-specific provisions that may be contingent upon meeting specific conditions, and the verification of those conditions is outside the scope of this report. These codes or standards often provide supplemental information as guidance.

4.0 DESIGN AND INSTALLATION

4.1 Design:

The veneer units described in this report comply with ASTM C1670 which is referenced in TMS 402-22 (for the 2024 IBC); 2021 and 2018 IBC Section 2103.1; and 2024, 2021 and 2018 IRC Section R606.2.6. The veneer units also comply with the unit dimensional limitations for prescriptively designed adhered veneer in Section 13.3.2.2 of TMS 402-22.

The saturated weight of the veneer units does not exceed 15 pounds per square foot (73.2 kg/m²). The weight of the mortar setting bed and scratch coat are outside the scope of this report.

Under the 2024 IBC and IRC, the detailing of the veneer must address the effects of differential movement, as required by Section 13.1 of TMS 402-22. Deflection of horizontal members supporting the veneer must be limited in accordance with Section 13.1.2.3 of TMS 402-22. Expected out-of-plane deflection of the supporting wall must comply with Section 13.3.1.2 of TMS 402-22.

For installation in accordance with the 2021, 2018 and 2015 IBC, supporting wall construction must be designed to support the weight of the veneer system. Horizontal framing members, such as lintels and headers, which support the veneer, must be designed to limit deflection to $1/600$ of the span.

Expansion or control joints used to limit the effect of differential movement of veneer supports must be specified by the architect, designer or veneer manufacturer, in that order. Consideration must be given to movement caused by temperature changes, shrinkage, creep and deflection.

In jurisdictions adopting the IRC, where the seismic provisions of Section R301.2.2 apply, the average weight of the wall supporting the veneer, including the weight of the veneer system, must be determined. When this weight exceeds the applicable limits of IRC Section R301.2.2.2, an engineered design of the wall construction must be performed in accordance with IRC Section R301.1.3.

4.2 Installation:

Installation of Eldorado Stone precast stone veneer must comply with this report, the manufacturer's published installation instructions, and the applicable code. The manufacturer's published installation instructions must be available at the jobsite at all times during installation. The veneer must be installed in accordance with IBC Section 1404.11 (2021 and 2018 IBC Section 1404.10; 2015 IBC Section 1405.10) or IRC Section R703.12, as applicable.

4.3 Special Inspection:

Under the 2024 IBC, special inspection requirements for installation of adhered masonry veneer are addressed in Table 4 of TMS 602-22, referenced in 2024 IBC Section 1705.4.

5.0 CONDITIONS OF USE:

The precast stone veneer described in this report complies with, or is a suitable alternative to what is specified in, those codes listed in Section 1.0 of this report, subject to the following conditions:

- 5.1 Installation must comply with this report, the manufacturer's published installation instructions and the applicable code. In the event of a conflict between the manufacturer's published installation instructions and this report, this report governs.
- 5.2 The veneer units must be manufactured and identified as described in this report.
- 5.3 Eldorado Stone products are manufactured under a quality control program with inspections by ICC-ES.

6.0 EVIDENCE SUBMITTED

- 6.1 Data in accordance with the [ICC-ES Acceptance Criteria for Adhered Manufactured Stone Masonry Veneer \(AC51\)](#), dated June 2018 (editorially revised February 2024).
- 6.2 Data addressing surface-burning characteristics in accordance with ASTM E84.

7.0 IDENTIFICATION

- 7.1 The ICC-ES mark of conformity, electronic labeling, or the evaluation report number (ICC-ES ESR-1215) along with the name, registered trademark, or registered logo of the report holder must be included in the product label.
- 7.2 In addition, boxes of veneer units are identified with the the brand name (Eldorado Stone), the style name and the color.
- 7.3 The report holder’s contact information is the following:

WESTLAKE ROYAL STONE LLC dba WESTLAKE ROYAL STONE SOLUTIONS
2801 POST OAK BOULEVARD, SUITE 600
HOUSTON, TEXAS 77056
(855) 769-2585
www.royalbuildingproducts.com/boral

TABLE 1—EVALUATED STYLES

PRODUCT	STYLES
Eldorado Stone®	Bluffstone, Cliffstone, Coastal Reef, Country Rubble, Cut Coarse Stone, Cypress Ridge, European Ledge, Fieldledge, Hillstone, Ledgecut ₃₃ , Limestone, Marquee ₂₄ , Mountain Ledge, Mountain Ledge Panel, Ridgetop ₁₈ , River Rock, Rivenwood, Roughcut, Rustic Ledge, Shadow Rock, Sierracut ₂₄ , Stacked Stone, Vantage ₃₀ , Zen 24
Eldorado Brick®	Loreiobrick, Tundra Brick
Eldorado Adobe®	Capistrano Adobe

DIVISION: 04 00 00—MASONRY**Section: 04 71 00—Manufactured Brick Masonry****Section: 04 73 00—Manufactured Stone Masonry****REPORT HOLDER:****WESTLAKE ROYAL STONE, LLC dba WESTLAKE ROYAL STONE SOLUTIONS****EVALUATION SUBJECT:****ELDORADO STONE®, ELDORADO BRICK® AND ELDORADO ADOBE® VENEERS****1.0 REPORT PURPOSE AND SCOPE****Purpose:**

The purpose of this evaluation report supplement is to indicate that Eldorado Stone®, Eldorado Brick® and Eldorado Adobe® Veneers, described in ICC-ES evaluation report [ESR-1215](#), have also been evaluated for compliance with the codes noted below.

Applicable code editions:

- 2025 and 2022 *California Building Code*® (CBC)

For evaluation of applicable Chapters adopted by the California Office of Statewide Health Planning and Development (OSHPD) AKA: California Department of Health Care Access and Information (HCAI) and the Division of State Architect (DSA), see Sections 2.1.1 and 2.1.2 below.

- 2025 and 2022 *California Residential Code*® (CRC)

2.0 CONCLUSIONS**2.1 CBC:**

The Eldorado Stone®, Eldorado Brick® and Eldorado Adobe® Veneers, described in Sections 2.0 through 7.0 of the evaluation report [ESR-1215](#), comply with 2025 CBC Sections 803.1.2, 1404.11.1, 1404.11.3, 2101.2.1 and 2103.1 (2022 CBC Sections 803.1.2, 1404.10.1, 1404.10.3, 2101.2.1 and 2103.1), provided the design and installation are in accordance with the 2024 and 2021 *International Building Code*® (IBC) provisions noted in the evaluation report and the additional requirements of CBC Chapter 14, as applicable.

2.1.1 OSHPD:

The applicable OSHPD Sections and Chapters of the CBC are beyond the scope of this supplement.

2.1.2 DSA:

The applicable DSA Sections and Chapters of the CBC are beyond the scope of this supplement.

2.2 CRC:

The Eldorado Stone®, Eldorado Brick® and Eldorado Adobe® Veneers, described in Sections 2.0 through 7.0 of the evaluation report [ESR-1215](#), comply with the flame spread and smoke developed requirements of CRC Section R302.9 and with CRC Sections R301, R606.2.6 and R703.12, provided the design and installation are in accordance with the 2024 and 2021 *International Residential Code*® (IRC) provisions noted in the evaluation report.

This supplement expires concurrently with the evaluation report, reissued November 2025.

DIVISION: 04 00 00—MASONRY**Section: 04 71 00—Manufactured Brick Masonry****Section: 04 73 00—Manufactured Stone Masonry****REPORT HOLDER:****WESTLAKE ROYAL STONE, LLC dba WESTLAKE ROYAL STONE SOLUTIONS****EVALUATION SUBJECT:****ELDORADO STONE®, ELDORADO BRICK® AND ELDORADO ADOBE® VENEERS****1.0 REPORT PURPOSE AND SCOPE****Purpose:**

The purpose of this evaluation report supplement is to indicate that Eldorado Stone, Eldorado Brick and Eldorado Adobe Veneers, described in ICC-ES evaluation report [ESR-1215](#), have also been evaluated for compliance with the codes noted below.

Applicable code editions:

- 2023 Florida Building Code—Building
- 2023 Florida Building Code—Residential

2.0 CONCLUSIONS

The Eldorado Stone, Eldorado Brick and Eldorado Adobe Veneers, described in ICC-ES evaluation report [ESR-1215](#), comply with the *Florida Building Code—Building* and the *Florida Building Code—Residential*. The design requirements must be determined in accordance with the *Florida Building Code—Building* and the *Florida Building Code—Residential*, as applicable. The installation requirements noted in ICC-ES evaluation report [ESR-1215](#) for the 2021 *International Building Code*® (IBC) meet the requirements of the *Florida Building Code—Building* and the *Florida Building Code—Residential*, under the following condition:

- Installation must be in accordance with FBC-B Section 1405.10 or FBC-R Section R703.12, as applicable.

Use of the Eldorado Stone, Eldorado Brick and Eldorado Adobe Veneers for compliance with the High-Velocity Hurricane Zone provisions of the *Florida Building Code—Building* and the *Florida Building Code—Residential* has not been evaluated, and is outside the scope of this evaluation report.

For products falling under Florida Rule 61G20-3, verification that the report holder's quality assurance program is audited by a quality assurance entity approved by the Florida Building Commission for the type of inspections being conducted is the responsibility of an approved validation entity (or the code official when the report holder does not possess an approval by the Commission). Florida Rule 61G20-3 is applicable to products and/or systems which comprise the building envelope and structural frame for compliance with the structural requirements of the Florida Building Code.

This supplement expires concurrently with the evaluation report, reissued November 2025.